

Watauga County Emergency Services

Smoke Detectors, Carbon Monoxide Detectors and Fire Extinguishers

Please fill out and return for each unit.

Smoke Detectors:

Number of smoke detectors:

| | | | | |
|----------------------------|--------|-------|--------|-------|
| Smoke detector: | Passed | _____ | Failed | _____ |
| Comb. Smoke / CO detector: | Passed | _____ | Failed | _____ |

If failed, then date fixed _____
How was it fixed? _____
New battery? _____
New unit? _____
Other? _____

Location requirements: Depends on the age of your residence.

Built before 1976: Needs battery or electric outside every sleeping area.

Between 1976 and 1999 Needs electric outside every sleeping area.

After 1999: Interconnected detectors inside every bedroom and in the area outside the sleeping area.

Carbon Monoxide Detectors:

Not applicable: **NO** fuel burning appliances in building _____ Please initial if true:

Number of CO detectors:

| | | | | |
|-------------------|--------|-------|--------|-------|
| Plug in or wired: | Passed | _____ | Failed | _____ |
| Battery: | Passed | _____ | Failed | _____ |

If failed, then date fixed:

How was it fixed? _____
New battery? _____
New unit? _____
Other? _____

Location requirements:

Inside dwelling units in the immediate vicinity of the sleeping areas if there are fuel burning appliances present.

Inside sleeping area if fuel burning appliance is inside or if fuel burning forced air furnace is present.

Fire Extinguisher:

906.2 Portable Fire Extinguisher shall be maintained in accordance with NFPA 10. Service to be done annually on Fire Extinguisher.

Size: Each unit should have a extinguisher of size 1A or larger near the cooking area.

Send in a copy of Fire Extinguisher service.

Name of person inspecting units: _____ Signature: _____